



NARODOWY
INSTYTUT
ZDROWIA
PUBLICZNEGO

PAŃSTWOWY INSTYTUT
BADAWCZY

ATEST HYGIENICZNY B.BK.60110.1605.2023



INSPECTION CERTIFICATE № 1708

Consignee, address: CANTAS IC VE DIS TICARET SOGUTMA SISTEMLERI SANAYI A.S.

Country Turkey

Contract № EX 23-008 dd 16.01.2023

We declare that the copper tube are produced according to standard indicated for each product as follow:

CUPPER TUBE REFERENCES

ORDER NUMBER AND DATE	SIZE	DESIGNATION AND TEMPER	STANDART REFERENCE
25-05 dd 19.08.2025r.	6,35x0,7x50 000	PANCAKE COILS ANNEALED	EN 12735-1

MECHANICAL TESTS

Tensile strength, σ , MPa (kgf/mm 2), not less than	Specific elongation δ %, not less than	Expansion %	Flattening	Hardness HV
239	38,8	40	comply with	55

CHIMICAL ANALYSIS

Cu-%	P-%	ALLOY
99,969	0,0204	Cu-DHP
Limit min 99,9	Limit min-0,012 max-0,040	

Dimensional tests-Measured values

WT. Av.-0,7	OD Av.-6,35
-------------	-------------

Angren Pipe Plant LLC
Akhangaran district 110300,
Tashkent region Republic Uzbekistan
Tel: +99893 183 53 83, e-mail: sales@angrenpipeplant.com
www.angrenpipeplant.com

Signature of the person responsible
Date 26.08.2025