



GB Access to set point and programming

AKO-D141xx/D101xx



AKO-D140xx



D Zugang Sollwert und Programmierung

AKO-D141xx/D101xx



AKO-D140xx




I Accesso al valore di riferimento e alla programmazione

AKO-D141xx/D101xx



AKO-D140xx



TR Ayar noktasına ve programlamaya erişim

AKO-D141xx/D101xx




AKO-D140xx



TR Доступ к уставке и к функции программирования

AKO-D141xx/D101xx



AKO-D140xx



D141H23B2 Ed.01



AKO-D14120 AKO-D14123 AKO-D14012
AKO-D14023 AKO-D14023-C AKO-D10123



GB Programming Menu (parameters)

After 20 seconds with no key being pressed, the equipment will return to the previous level. If you are on level 3, the changes will not be saved.

D Programmiermenü (Parameter)

Nach 20 Sekunden ohne Betätigung einer Taste stellt sich das Gerät in die zuvor verwendete Ebene zurück. Wenn sich das Gerät auf Ebene 3 befindet, werden die Änderungen nicht gespeichert.

I Menu di programmazione (parametri)

Se non viene premuto nessun tasto per 20 secondi, il dispositivo ritorna al livello precedente. Nel caso in cui ci si trovi al livello 3, le modifiche non verranno salvate.

TR Programlama menüsü (parametreler)


20 saniye boyunca hiçbir tuşa basılmazsa, cihaz önceki seviyeye dönecektir. 3. seviyede ise, değişiklikler kaydedilmeyecektir.

RU Меню программирования (параметров)


По истечении 20 с без нажатия какой-либо из клавиш устройство возвратится на прежний уровень.

В случае нахождения на уровне 3 изменения не сохраняются.


AKO-D141xx/D101xx



AKO-D140xx



Change set point / Änderung des Sollwerts (Set Point)
Modifica del valore di riferimento (Set Point) / Ayar noktasını değiştirme (Ayar noktası) / Изменение значения уставки (Set Point)



- A** Temperature Indication / Temperaturanzeige / Indicazione temperatura / Sıcaklık göstergesi / Индикация температуры
- B** Level 1 Menu / Ebene 1 Menü / Livello 1 Menu / 1. Seviye Menüler / Уровень 1 Меню
- C** Level 2 Parameters / Ebene 2 Parameter / Livello 2 Parametri / 2. Seviye Parametreler / Уровень 2 Параметры
- D** Level 3 Values / Ebene 3 Werte / Livello 3 Valori / 3. Seviye Değerler / Уровень 3 Значения
- E** Current Value / Aktueller Wert / Valore attuale / Mevcut değer / Текущее значение
- F** New Value / Neuer Wert / Nuovo valore / Yeni değer / Новое значение

AKO Av. Roquetes, 30-38
08812 Sant Pere de Ribes
Barcelona (Espanya)
Tel. (34) 938 142 700
Fax (34) 938 934 054
www.ako.com
ako@ako.com

AKO ELECTROMECÁNICA, S.A.L.
We reserve the right to supply materials which may be slightly different from those described in our Data Sheets. Updated information on our web site.
Wir behalten uns das Recht auf die Lieferung von Materialien vor die leicht von den Materialien abweichen können, die in unserer technischen Dokumentation beschrieben sind. Aktualisierte Informationen erhalten Sie auf.
L'azienda si riserva il diritto di fornire materiali che potrebbero essere leggermente diversi da quelli descritti nelle Schede tecniche. Informazioni aggiornate sul nostro sito web.
Teknik Dokümanlarımızda açıklananlara nazaran küçük farklılıklar gösteren malzemeler sunma hakkımız saklıdır. Web sitemizden güncel bilgilere erişebilirsiniz.
Мы оставляем за собой право на поставку материалов, которые могут несколько отличаться от описанных в наших технических условиях. Обновленную информацию можно получить на нашем вебсайте.

GB Table of parameters and messages

Def. column shows factory-set default parameters. Those marked with * are variable parameters depending on the application chosen in the wizard. Unless otherwise stated, temperatures are expressed in °C. (Equivalent values in °F)

AKO-D14023-C				
AKO-D14012, AKO-D14023				
AKO-D14120, AKO-D14123, AKO-D10123				
Level 1	Menus and description			
rE	Level 2	Control	Values	Min. Def. Max.
	Level 3	Description		
	SP	Temperature Adjustment (Set Point) (limits depending on probe type)	With NTC (°C/°F) With PTC	-50.0 * (-58°F) - 150 (302°F)
	C0	Calibrating probe 1 (Offset)	(°C/°F)	-20.0 0.0 20.0
	C1	Probe 1 differential (Hysteresis)	(°C/°F)	0.1 2.0 20.0
	C2	Upper blocking of the set point (cannot be set above this value)	With NTC (°C/°F) With PTC	99.9 * (210°F) - 150 (302°F)
	C3	Lower blocking of the set point (cannot be set below this value)	(°C/°F)	-50.0 * (-58°F) -50.0 C2
	C4	Type of delay for protection of the compressor: 0=OFF/ON (since the last disconnection) 1=OFF-ON/ON-OFF (since the last shut-down/start-up)		0 0 1
	C5	Protection delay time (value of the option selected in parameter C4)	(min.)	0 0 120
	C6	Status of COOL relay with probe fault 0=OFF; 1=ON; 2=Average based on last 24 hours prior to probe fault		0 2 2
	EP	Exit to Level 1		
dEF	Level 2	DEFROST Control (if P0=0 Direct, Cold)		
	Level 3	Description	Values	Min. Def. Max.
	d0	Defrost frequency (Time between two starts)	(h.)	0 * 96
	d1	Maximum defrost duration (0=defrost deactivated)	(min.)	0 255
	d2	Type of message during defrost: 0=Current temperature; 1=Temperature at start of defrost; 2=Display dEF message		0 2 2
	d3	Maximum duration of message (time added at the end of the defrost)	(min.)	0 5 255
	EP	Exit to Level 1		

AKO-D14023-C				
AKO-D14012, AKO-D14023				
AKO-D14120, AKO-D14123, AKO-D10123				
CnF	Level 2	General status		
	Level 3	Description	Values	Min. Def. Max.
	P0	Type of operation 0=Direct, Cold; 1=Inverted, Heat	0 *	1
	P1	Delay of all functions on receiving electrical power	(min.)	0 0 255
	P2	Access code (password) functions 0=Inactive; 1=Block access to parameters; 2=Keyboard lock		0 0 2
	P5	Address (only systems with built-in communications)		1 1 255
	P7	Temperature display mode 0=Integer °C 1=One decimal in °C 2=Integer °F 3=One decimal in °F		0 1 3
	P9	Selection of probe type 0=NTC; 1=PTC		0 0 1
	EP	Exit to Level 1		
tid	Level 2	Access and information control		
	Level 3	Description	Values	Min. Def. Max.
	L5	Access code (Password)		0 - 99
	PU	Program version (Information)		-
	Pr	Program revision (Information)		-
	EP	Exit to Level 1		

MESSAGES			
L5	Access code (Password) request		D
dEF	Indicates a defrost is underway. (Only if parameter d2=2)		D -
E1	Probe 1 faulty (open circuit, crossover, NTC: temp. > 110°C or < -55°C PTC: temp. > 150°C or < -58°C) - (equivalent limits in °F)		D S
InI	Setup wizard (See section "Start-up")		D

D: Displays the message on the display
S: Shows the message in the AKONet software (Only AKO-D14023-C)

35D14123B2 REV.00 2014

